

IES Report

ZipThree® | 707 | 85° Asymmetric , downlight only | 80 CRI | HO

707-Z3-4-48-XX-XX-X-0-Z-HO-35-A1-X-AL / WH-X

	2700K	3000K	3500K	4000K
Efficacy - Lumens per Watt	91	94	96	96
Total Lumens, 4' rail length (1219mm)	4864	5018	5120	5120
Lumens per foot (305mm)	1216	1254	1280	1280
Input Power (W), 4' rail length (1219mm)	53.8	53.8	53.8	53.8
Watts per foot (305mm)	13.5	13.5	13.5	13.5
CRI	82	82	82	82

Due to the large number of options in Vode's product offering, most Vode IES reports are factored reports prepared from source reports. Source reports are the IES test reports prepared for Vode by an NVLAP accredited photometric test laboratory. Factored reports are based on data from the Vode source reports.

If the data above is in black, it is directly from a Vode source report. If it is in grey, it is factored from Vode source reports. Reference details on Vode source reports can be found on the [IES File Finder](#) page on [vode.com](#).



IES INDOOR REPORT

PHOTOMETRIC FILENAME : VODE_707_Z3_HO_35_A1.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] L121911543 (SOURCE REPORT FOR REFERENCE)

[TESTLAB] REPORT BASED ON DATA FROM NVLAP ACCREDITED LAB

[ISSUE DATE] 12/23/2019

[MANUFAC] Vode Lighting

[LUMCAT] 707-Z3-48-Z-HO-35-A1-AL

[LUMINAIRE] ZipThree LED, 48", 3500K, 80 CRI, zipper board, 85° asymmetric lens down,

[MORE] high output, clear anodized finish

[TEST PROCEDURE] IESNA:LM-79-08

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	5111
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	95
Total Luminaire Watts	53.83
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.70
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	1.28
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	0.04 ft
Luminous Width (90-270)	3.98 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	201127	194612	124627
55	180068	175923	109077
65	151204	146984	89667
75	121152	115410	68327
85	85254	76729	42627

IES INDOOR REPORT
PHOTOMETRIC FILENAME : VODE_707_Z3_HO_35_A1.IES

CANDELA TABULATION

	<u>0</u>	<u>5</u>	<u>10</u>	<u>15</u>	<u>20</u>	<u>25</u>	<u>30</u>	<u>35</u>	<u>40</u>	<u>45</u>
0	2096.6	2096.6	2096.6	2096.6	2096.6	2096.6	2096.6	2096.6	2096.6	2096.6
5	2336.4	2334.2	2332.0	2327.6	2321.0	2314.4	2305.6	2294.6	2281.4	2266.0
10	2552.0	2552.0	2547.6	2541.0	2527.8	2514.6	2497.0	2477.2	2453.0	2426.6
15	2692.8	2690.6	2686.2	2675.2	2662.0	2644.4	2624.6	2598.2	2567.4	2534.4
20	2758.8	2756.6	2750.0	2741.2	2728.0	2708.2	2686.2	2659.8	2626.8	2589.4
25	2747.8	2750.0	2743.4	2734.6	2721.4	2706.0	2684.0	2659.8	2624.6	2589.4
30	2679.6	2677.4	2673.0	2664.2	2653.2	2640.0	2620.2	2598.2	2567.4	2532.2
35	2545.4	2545.4	2541.0	2534.4	2525.6	2514.6	2499.2	2479.4	2453.0	2420.0
40	2349.6	2349.6	2345.2	2343.0	2336.4	2327.6	2316.6	2301.2	2279.2	2255.0
45	2105.4	2105.4	2103.2	2101.0	2096.6	2092.2	2083.4	2074.6	2057.0	2037.2
50	1826.0	1826.0	1823.8	1821.6	1819.4	1815.0	1810.6	1804.0	1793.0	1777.6
55	1529.0	1529.0	1526.8	1526.8	1524.6	1522.4	1518.0	1513.6	1504.8	1493.8
60	1229.8	1229.8	1229.8	1227.6	1227.6	1223.2	1221.0	1216.6	1210.0	1201.2
65	946.0	946.0	946.0	946.0	943.8	941.6	937.2	935.0	928.4	919.6
70	693.0	693.0	693.0	690.8	688.6	686.4	684.2	679.8	675.4	668.8
75	464.2	464.2	464.2	462.0	462.0	459.8	455.4	453.2	448.8	442.2
80	270.6	270.6	268.4	268.4	266.2	266.2	264.0	259.6	255.2	250.8
85	110.0	110.0	110.0	107.8	107.8	107.8	105.6	103.4	101.2	99.0
90	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Vert. Angles **Horizontal Angles**

	<u>50</u>	<u>55</u>	<u>60</u>	<u>65</u>	<u>70</u>	<u>75</u>	<u>80</u>	<u>85</u>	<u>90</u>	<u>95</u>
0	2096.6	2096.6	2096.6	2096.6	2096.6	2096.6	2096.6	2096.6	2096.6	2096.6
5	2252.8	2235.2	2217.6	2197.8	2178.0	2158.2	2136.2	2112.0	2090.0	2068.0
10	2395.8	2362.8	2327.6	2290.2	2250.6	2206.6	2160.4	2112.0	2065.8	2013.0
15	2494.8	2448.6	2400.2	2347.4	2290.2	2226.4	2160.4	2090.0	2017.4	1942.6
20	2543.2	2492.6	2435.4	2371.6	2301.2	2219.8	2136.2	2048.2	1951.4	1854.6
25	2543.2	2488.2	2426.6	2356.2	2274.8	2184.6	2085.6	1980.0	1863.4	1744.6
30	2488.2	2435.4	2373.8	2301.2	2215.4	2116.4	2008.6	1889.8	1757.8	1619.2
35	2382.6	2332.0	2274.8	2204.4	2116.4	2013.0	1900.8	1773.2	1628.0	1478.4
40	2222.0	2178.0	2125.2	2054.8	1973.4	1874.4	1757.8	1628.0	1478.4	1322.2
45	2010.8	1975.6	1929.4	1867.8	1793.0	1696.2	1586.2	1456.4	1304.6	1155.0
50	1757.8	1727.0	1687.4	1636.8	1570.8	1485.0	1379.4	1260.6	1124.2	979.0
55	1476.2	1454.2	1421.2	1379.4	1322.2	1247.4	1157.2	1047.2	926.2	803.0
60	1188.0	1168.2	1144.0	1108.8	1062.6	1001.0	924.0	836.0	730.4	638.0
65	910.8	895.4	873.4	847.0	809.6	763.4	704.0	635.8	561.0	479.6
70	660.0	649.0	631.4	611.6	585.2	550.0	506.0	455.4	400.4	343.2
75	435.6	426.8	415.8	400.4	382.8	358.6	330.0	297.0	261.8	226.6
80	246.4	239.8	233.2	224.4	213.4	200.2	184.8	165.0	145.2	127.6
85	96.8	92.4	90.2	85.8	81.4	74.8	70.4	63.8	55.0	48.4
90	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Vert. Angles **Horizontal Angles**

	<u>100</u>	<u>105</u>	<u>110</u>	<u>115</u>	<u>120</u>	<u>125</u>	<u>130</u>	<u>135</u>	<u>140</u>	<u>145</u>
0	2096.6	2096.6	2096.6	2096.6	2096.6	2096.6	2096.6	2096.6	2096.6	2096.6
5	2043.8	2021.8	1999.8	1977.8	1955.8	1936.0	1918.4	1898.6	1883.2	1870.0
10	1964.6	1916.2	1865.6	1819.4	1773.2	1727.0	1685.2	1645.6	1612.6	1579.6
15	1865.6	1790.8	1713.8	1643.4	1570.8	1504.8	1443.2	1388.2	1337.6	1291.4
20	1751.2	1652.2	1553.2	1458.6	1366.2	1284.8	1210.0	1139.6	1080.2	1027.4
25	1625.8	1500.4	1381.6	1273.8	1166.0	1073.6	992.2	917.4	855.8	800.8
30	1482.8	1344.2	1210.0	1091.2	976.8	880.0	798.6	726.0	666.6	616.0
35	1331.0	1179.2	1040.6	917.4	803.0	712.8	635.8	569.8	514.8	473.0

IES INDOOR REPORT
PHOTOMETRIC FILENAME : VODE_707_Z3_HO_35_A1.IES

CANDELA TABULATION - (Cont.)

40	1168.2	1016.4	877.8	759.0	651.2	569.8	501.6	442.2	400.4	367.4
45	1003.2	858.0	726.0	618.2	521.4	451.0	393.8	347.6	314.6	290.4
50	838.2	706.2	589.6	495.0	415.8	356.4	312.4	277.2	250.8	233.2
55	684.2	569.8	473.0	393.8	330.0	283.8	248.6	222.2	202.4	189.2
60	539.0	444.4	369.6	308.0	257.4	222.2	195.8	176.0	162.8	151.8
65	404.8	336.6	279.4	233.2	198.0	171.6	151.8	138.6	127.6	118.8
70	290.4	242.0	202.4	169.4	145.2	127.6	114.4	103.4	94.6	90.2
75	193.6	162.8	136.4	114.4	99.0	88.0	79.2	72.6	66.0	63.8
80	107.8	92.4	77.0	68.2	59.4	52.8	48.4	44.0	41.8	39.6
85	41.8	37.4	33.0	28.6	26.4	24.2	22.0	19.8	19.8	17.6
90	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Vert. Horizontal Angles

	<u>150</u>	<u>155</u>	<u>160</u>	<u>165</u>	<u>170</u>	<u>175</u>	<u>180</u>
0	2096.6	2096.6	2096.6	2096.6	2096.6	2096.6	2096.6
5	1856.8	1845.8	1834.8	1828.2	1823.8	1819.4	1819.4
10	1551.0	1529.0	1509.2	1493.8	1482.8	1474.0	1471.8
15	1251.8	1221.0	1194.6	1170.4	1157.2	1148.4	1144.0
20	981.2	946.0	915.2	893.2	875.6	866.8	862.4
25	754.6	721.6	690.8	668.8	653.4	644.6	642.4
30	576.4	543.4	519.2	499.4	488.4	479.6	477.4
35	440.0	413.6	393.8	378.4	369.6	363.0	363.0
40	341.0	321.2	308.0	297.0	290.4	286.0	283.8
45	270.6	257.4	246.4	237.6	233.2	231.0	228.8
50	217.8	209.0	200.2	195.8	193.6	191.4	189.2
55	180.4	171.6	167.2	162.8	160.6	160.6	158.4
60	145.2	138.6	136.4	132.0	132.0	129.8	129.8
65	114.4	110.0	107.8	105.6	103.4	103.4	103.4
70	85.8	83.6	81.4	79.2	77.0	77.0	77.0
75	59.4	57.2	57.2	55.0	55.0	55.0	55.0
80	37.4	37.4	35.2	35.2	35.2	35.2	35.2
85	17.6	17.6	17.6	17.6	17.6	17.6	17.6
90	0.0	0.0	0.0	0.0	0.0	0.0	0.0

IES INDOOR REPORT
PHOTOMETRIC FILENAME : VODE_707_Z3_HO_35_A1.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	751.02	N.A.	14.70
0-30	1564.62	N.A.	30.60
0-40	2512.52	N.A.	49.20
0-60	4226.2	N.A.	82.70
0-80	5038.04	N.A.	98.60
0-90	5111.02	N.A.	100.00
10-90	4913.6	N.A.	96.10
20-40	1761.5	N.A.	34.50
20-50	2696.44	N.A.	52.80
40-70	2247.14	N.A.	44.00
60-80	811.84	N.A.	15.90
70-80	278.38	N.A.	5.40
80-90	72.98	N.A.	1.40
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	5111.02	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	197.42
10-20	553.61
20-30	813.60
30-40	947.90
40-50	934.94
50-60	778.74
60-70	533.46
70-80	278.38
80-90	72.98
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00


IES INDOOR REPORT
PHOTOMETRIC FILENAME : VODE_707_Z3_HO_35_A1.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	105	101	97	107	103	99	96	98	95	93	95	92	90	91	89	87	85
2	100	92	86	80	97	90	84	79	87	82	77	84	79	76	81	77	74	72
3	92	81	74	67	89	80	73	67	77	71	66	74	69	65	72	67	63	61
4	84	73	64	58	82	71	63	57	69	62	56	66	61	56	64	59	55	53
5	78	65	56	50	75	64	56	50	62	55	49	60	54	49	58	53	48	46
6	72	59	50	44	70	58	50	44	56	49	43	54	48	43	53	47	43	41
7	67	53	45	39	65	53	45	39	51	44	39	50	43	38	48	42	38	36
8	62	49	41	35	61	48	40	35	47	40	35	46	39	34	45	39	34	32
9	58	45	37	32	57	44	37	31	43	36	31	42	36	31	41	35	31	29
10	55	42	34	29	53	41	34	29	40	33	28	39	33	28	38	32	28	27

POLAR GRAPH



Maximum Candela = 2758.8 Located At Horizontal Angle = 0, Vertical Angle = 20

1 - Vertical Plane Through Horizontal Angles (0 - 180)

2 - Horizontal Cone Through Vertical Angle (20) (Through Max. Cd.)